



CITY OF HOUSTON

Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE
Director
P.O. Box 61167
Houston, Texas 77208-1167
3300 Main
Houston, Texas 77002

T. 713.837.0037
F. 713.837.0040
www.cityofhouston.gov

October 4, 2004

Mr. Carl Parker
Blucher-Josam
2501 S. Front St.
Philadelphia, PA 19148

RE: Approval of Stainless Steel Pipe

Dear Mr. Parker:

You are hereby notified that the Plumbing Review Board, at their meeting on Thursday, September 23, 2004, voted to interpret that the product, 304 and/or 316L stainless steel pipe, will meet and/or exceed the requirements of the City of Houston Plumbing Code. Stainless steel pipe meeting the ASME A112-3:1 1993, will be accepted. The 304 stainless steel pipe above ground and 316L stainless steel pipe above or below ground for use of sanitary, drainage, storm drainage, vent systems, acid waste systems, vacuum drainage systems, venting systems with sanitary and acid systems will meet and/or exceed the requirements of the City of Houston Plumbing Code.

If you have any questions you may contact Maria Hernandez at 713-535-7535.

Respectfully,

Handwritten signature of John J. Roth in cursive.

John J. Roth, Secretary
Plumbing Review Board

JJR:mh

Xc: Wayne Harrison, Code Specialist
Richard Cabrera