



City of Chicago
Richard M. Daley, Mayor

Department of Buildings

Norma I. Reyes
Commissioner

City Hall, Room 501
21 North LaSalle Street
Chicago, Illinois 60602
(12) 744-3400
(12) 744-0682 (FAX)
(12) 744-2951 (TTY)

Technical & Conservation
Inspection Services
240 West Ogden Avenue
Chicago, Illinois 60612
(12) 742-7089
(12) 746-8272 (FAX)

<http://www.cityofchicago.org>

April 14, 2003

To: Wayne Harrison
Josam Industries
1709 Parklane Dr
Edmond, OK 73003

From: Kevin Bush
Chief Plumber Inspector
2240 W. Ogden (3rd fl)
Chicago, Illinois 60612

RE: Josam Super-Flo G.I. 2000
Grease Recovery Device

This is in response regarding the above mentioned. Mr. Harrison after review of your product literature for Josam Super-Flo G.I. 2000 (GRD) and conferring with the Department of Water and Sewers. The above mentioned Grease Interceptors have been approved for use in the City of Chicago.

All installations must conform to 18-29-1003 of the Chicago Plumbing Code.
All Interceptors models must conform to PDI G101 (18-29-1003.3.8)

Very truly yours.

Kevin Bush
Chief Plumber Inspector

KB/dl

NEIGHBORHOODS

