



**CITY OF HOUSTON**  
Public Works and Engineering Department

**Bill White**

Mayor

Michael S. Marcotte, P.E., DEE  
Director  
P.O. Box 61167  
Houston, Texas 77208-1167  
3300 Main  
Houston, Texas 77002

T. 713.837.0037  
F. 713.837.0040  
[www.cityofhouston.gov](http://www.cityofhouston.gov)

October 4, 2004

Mr. Carl Parker

2501 S. Front St.  
Philadelphia, PA 19148

**RE: Approval of Grease Trap**

Dear Mr. Parker:

You are hereby notified that the Plumbing Review Board, at their meeting on Thursday, September 23, 2004, voted to interpret that the automatic grease/oil removal device, known as GRD plumbing appliance, is equal to and/or exceeds the requirements of the City of Houston Plumbing Code, to be installed in a grease waste system to intercept grease, cooking oils, and fats from wastewater discharge without intervention from the user except normal maintenance. The size shall be according to the manufactures recommendation and also as approved by the authority having jurisdiction.

If you have any questions you may contact Maria Hernandez at 713-535-7535.

Respectfully,

Handwritten signature of John J. Roth in cursive.

John J. Roth, Secretary  
Plumbing Review Board

JJR:mh

Xc: Wayne Harrison, Code Specialist  
Richard Cabrera