

Frank L. O'Bannon
Governor

Richard D. Feldman, M.D.
State Health Commissioner



Indiana State Department of Health

An Equal Opportunity Employer

June 26, 2000

Mr. Chas Tevis
Director of Engineering
Josam Philadelphia
2501 South Front Street
Philadelphia, PA 19148

Dear Mr. Tevis:

Re: JOSAM
GI2 000 Grease Interceptor System
A. GI2 000 Solids Interceptor Unit
B. GI2 000 Series 60300 Interceptor Unit
C. GI2 000 Series 60300 Reclaim Tank Unit
D. JOSAM Flow Control

This will confirm receipt of manufacturer specifications for the JOSAM GI 2000 Grease Interceptor System.

After reviewing the submittal, we will offer no objections to the installation of the aforementioned "system" in school facilities in accordance with Rule 410 IAC 6-5.1-6(e) providing the reclaim tank unit is accessible for maintenance and cleaning from outside the building.

If you have any questions, please contact Dennis H. Ehlers of this office at AC 317/233-7177.

Sincerely,

HOWARD W. CUNDIFF, P.E., DIRECTOR
CONSUMER PROTECTION

DHEhlers/kk

cc: Plan Review Staff